

* all units in m ³ /day	Rated (C of A) Capacity	2021 Estimated Capacity	2017 – 2021 Average Production	Remaining Capacity (Estimated Capacity – Average Production)	Infill Development Reserve Allocation (5% of Remaining Capacity)	Total Recommended Capacity (Includes allocated and requested Capacity)	Total Capacity Remaining after Infill Reserve and Recommended Allocation
Waste Water							
Caledonia	7,200	7,200	3,214	3,986	199	2,636	1,151
Cayuga	1200	1200	813	387	19	228	141
Dunnville	7,728	7,728	4,542	3,186	159	769	2,258
Hagersville	4,200	4,200	2,500	1,700	85	1,087	528
Jarvis Lagoon	853	853	1,009	-	-	469	0
Townsend Lagoon	2,095	2,095	276	1,819	91	163	1,565
LEIP Lagoon	657	657	738	-	-	0	0
Water							
Nanticoke	13,600	13,600	9407 ²	4,193	210	1,516	2,467
Dunnville ¹	14,500	S*: 14,500	5551 ²	4,449	222	809	3,418
		W*:10,000					
Caledonia/Cayuga (Hamilton Supply)	n/a	13,800	4765 ²	9,035	452	3,685	4,899

Notes:

1. Colder water temperatures in winter months limits disinfection capability.
2. Water production shown as max day based on a 95th percentile basis.